



GOVERNMENT OF ARUNACHAL PRADESH  
OFFICE OF THE ASSISTANT ENGINEER:.....PHE & WS DEPARTMENT  
SUB-DIVISION : PASIGHAT

WATER QUALITY TEST REPORTs OF ST. Thomas Residential School Pasighat

No. AE/PHE/PSG/Lab-01/2025-26

Dated Pasighat the 19<sup>th</sup> February'2026

Sl.No	Source Type	Date of Test	ALKALINITY	FLUORIDE	TOTAL HARDNESS	IRON	p <sup>H</sup> Value	CHLORIDE	NITRATE	SULPHATE	TDS	TURBIDITY	BACTERIOLOGICAL TEST
1	Ringwell	18-02-2026	25.0 mg/l	0.06 mg/l	0.00 mg/l	0.15 mg/l	6.8	1.2 mg/l	0.176 mg/l	8.0 mg/l	1.33 ppm	0.07 NTU	0
Acceptable Range			200 mg/l	1.5 mg/l	200 mg/l	0.3 mg/l	6.5 - 8.5	250 mg/l	45 mg/l	200 mg/l	500 mg/l	5.00NTU	0

Result :- All the Parameters found are Normal

  
Lab-Technician

PHE & WS Sub-Division, Pasighat

  
19/2/26  
Assistant Engineer  
Assistant Engineer  
PHE & WS Sub-Division, Pasighat  
PHE & WS Sub-Division  
Pasighat